



In Cooperation with



*Most Widely Accepted and Trusted*

# ICC-ES Report

## PMG-1438

Reissued 08/2018

ICC-ES | (800) 423-6587 | (562) 699-0543 | [www.icc-es.org](http://www.icc-es.org)

This report is subject to renewal 08/2019

EVALUATION SUBJECT:

## AQUATECHNIK GAS PEX-AL-PEX PIPE AND FITTING SYSTEM

**DIVISION:**

23 00 00—HEATING, VENTILATING AND AIR CONDITIONING (HVAC)

**SECTION:**

23 11 00—FACILITY FUEL PIPING

Report Holder:

**AQUATECHNIK GROUP S.P.A**

Look for the ICC-ES marks of Conformity!



ICC-ES Evaluation Reports are not to be construed as representing aesthetics or any other attributes not specifically addressed, nor are they to be construed as an endorsement of the subject of the report or a recommendation for its use. There is no warranty by ICC Evaluation Service, LLC, express or implied, as to any finding or other matter in this report, or as to any product covered by the report. Copyright © 2018 ICC Evaluation Service, LLC. All rights reserved.



## ICC-ES PMG Product Certificate

**PMG-1438**



Effective Date: August 2018

This listing is subject to re-examination in one year.

[www.icc-es-pmg.org](http://www.icc-es-pmg.org) | (800) 423-6587 | (562) 699-0543 A Subsidiary of the International Code Council®

CSI: DIVISION: 23 00 00—HEATING, VENTILATING AND AIR CONDITIONING (HVAC)  
Section: 23 11 00—Facility Fuel Piping

### Product certification system:

The ICC-ES product certification system includes testing samples taken from the market or supplier's stock, or a combination of both, to verify compliance with applicable codes and standards. The system also involves factory inspections, and assessment and surveillance of the supplier's quality system.

Products: Aquatechnik Gas PEX-AL-PEX Pipe and Fitting System

Listee: Aquatechnik Group s.p.a  
Via P.F. Calvi, 40  
Magnago (MI) 20020 Italy  
[www.aquatechnik.it](http://www.aquatechnik.it)  
[www.aquatechnikNA.com](http://www.aquatechnikNA.com)

### Compliance with the following codes:

2018, 2015, 2012 and 2009 *International Fuel Gas Code*® (IFGC)  
2018, 2015, 2012 and 2009 *International Residential Code*® (IRC)  
2018, 2015, 2012 and 2009 *Uniform Plumbing Code*® (UPC)\*

\*Copyrighted publication of the International Association of Plumbing and Mechanical Officials.

### Compliance with the following standards:

ASTM F1281-2017, Standard Specification for Cross-linked Polyethylene/Aluminum/Cross-linked Polyethylene (PEX-AL-PEX) Pressure Pipe

### Identification:

**Pipe:** The Aquatechnik PEX-AL-PEX pipe shall be marked every 5 feet (1.5 m) with the following: company name or trademark, material (PEX-AL-PEX), nominal size (for example, 1216), temperature and pressure ratings, ASTM F1281 designation, production code, and the ICC-ES PMG listing mark.

**Fittings:** Fittings shall be marked with manufacturer's name or trademark, and the ICC-ES PMG listing mark.

### Installation:

Aquatechnik PEX-AL-PEX pipes must be installed in accordance with the manufacturer's published installation instructions, the applicable codes and this listing.